

Addendum 4
10/24/2020

Questions that were brought up concerning the LaPorte County Infrastructure Project.

1. Which format do you want turned in with the bid?

Use the excel spread sheet format. This is the updated bid tab.

2. Does the ductile iron pipe that is being used on the gravity sanitary sewer need to be 401 lined? The Bid Bond has "LaPorte Water Main" as project title. Does this need to be changed to match project name?

Where specified DIP 401 lined pipe shall be used for all sanitary sewer applications. Gravity Lift, Station or Forced main.

3. Will the bid date be delayed?

No. Sealed Bids for the construction of the La Porte County Water & Sewer (SR 421 & CR 300 North Utility Extensions) Project will be received, by the County, at La Porte County Community Development Commission (555 Michigan Ave., La Porte, IN. 46350) until 3:00 PM local time on Wednesday, October 28th, at which time the Bids received will be publicly opened and read aloud. Bids will be reviewed by the LaPorte County Engineer and Attorney and the successful low bid Contractor will be awarded at a subsequent meeting room at the La Porte City Complex Building Rm #3 on Wednesday, December 23rd at 4:00 Local time..

4. Will "Field Locking Gaskets" or TR Flex be allowed for carrier pipe installation for the water main Jack and Bores?

Field locking gaskets or TR Flex will be required for the carrier pipe.

The casing pipe will need to be one piece or welded.. The ends will need to be sealed. See detail sheet C523

5. CLARIFICATION 34. Bid items W5, W6 & W7 of lines A1 and A2, is this just the labor to perform the jack and bore and material to install the casing pipe, spacers and end seals only and the carrier pipe material will be paid for under line item W1? Please check your quantities since the quantity of pipe listed in W1 is for all of the pipe shown on lines A1 & A2.

The lineal foot of water main pipe used will be paid for on a LF installed basis.

*The Jack and Bore line items shall include all necessary costs to install the **Casing Pipe not Carrier Pipe** for the main water line.*